

**CITY OF HENDERSONVILLE
FRENCH BROAD RIVER INTAKE AND PUMPING STATION PROJECT**

ADDENDUM NO. 2

September 9, 2021

- A. SCOPE.** This Addendum No. 2 consists of page AD2-1 and covers the following additions and changes to the Specifications and Drawings for this Project and contains the following attachments.
- B. DRAWINGS.**
1. Sheet C-99-502 – Detail G Typical King Pile and Raker Pile Cap Detail. After “3/8” Plate Stiffener ES” DELETE “(Welded to king pile)” and REPLACE with “Cut to fit the open area between the flanges of the pile and the web, welded to the king pile on three sides.”
- C. ACKNOWLEDGEMENT BY BIDDER.** Each Bidder is required to acknowledge receipt of this Addendum No. 2 in the space provided in the Bid Form.