

Water System-Supplied Information

Information on this page must be updated on an annual basis

Data provided by: _____ (name) Date provided: _____

Position: _____

Number of current connections in water system	_____connections
Approved number of connections in water system	_____connections <input type="checkbox"/> N/A – local government system
Current average and maximum daily demand of existing system. Average day demand is the one day average demand for the latest calendar year.	_____average gpd _____maximum gpd
Current maximum daily treated water supply of existing system Maximum daily treated water supply is the maximum quantity of treated water that can be produced and/or purchased by the system.	_____maximum gpd
Total elevated storage capacity of existing system	_____gallons
Total ground storage capacity of existing system	_____gallons
Total hydropneumatic storage capacity of existing system	_____gallons
Contractual storage with other system(s) Attach a copy of the agreement with the providing system	_____gallons
<p>Systems > 300 connections:</p> <ul style="list-style-type: none"> • Total storage volume is at least half the average annual daily demand (Rule .0805(c)) • For municipalities, at least 75,000 gallons elevated storage and at least half the average day demand combined elevated and ground finished water storage (Rule .0805(b)) <p>Systems with hydropneumatic storage tanks up to 300 connections:</p> <ul style="list-style-type: none"> • Volume of hydropneumatic storage tank is sufficient to meet peak demands based on Rule .0802 and calculations in Appendix B, Figure 6 • For residential community systems, volume of hydropneumatic storage tank is at least 40 times the number of connections or 500 gallons, whichever is greater (Rule .0803) • For mobile home park systems, volume of hydropneumatic storage tank is at least 25 times the number of connections or 500 gallons, whichever is greater (Rule .0803) • For campground systems, volume of hydropneumatic storage tank is at least 10 times the number of connections or 500 gallons, whichever is greater (Rule .0803) 	<p><input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A</p>